

- I. Pre-cut exp. joint's material shall be used in all exp. joints.
- 2.Dummy joints shall be installed at IOft. intervals, maximum.

- 3.Exp. joints shall be installed at 40ft.,maximum.
 4.Exp. joints shall be installed at ends of radius.
 5.Exp. joints shall be located a minimum of 5ft. from inlet structures.

Conc. to be CLASS 'A' (6bag min)

Slope 3/16" per ft. or same slope as pavement

REVISIONS			
NO.	DATE	BY	REMARKS
ı	5-30-85	L.R.H.	REMOVED DIV. OF PUBLIC WORKS (T. BLK.)
2	7-7-87		REMOVED 3000 PSI, ADDED CLASS 'A'
3	1-29-88	D.H.G	REMOVE DEPARTMENT (T. BLK.)
	4		

CONVERSIONS METRIC ENGLISH

CITY OF MEMPHIS DIVISION OF ENGINEERING

DESIGN STANDARD FOR

6-18 MEDIAN CURB

7-J-79 DATE DEPUTY DIRECTOR/ CIVIL ENGINEER DATE