



NOTE: Concrete to be CLASS 'A'
(6 bag min.)

REVISIONS

NO.	DATE	BY	REMARKS
1	Feb. 1984	RTH	Change width from 30" to 33"
2	5-30-85	L.R.H.	REMOVED DIV. OF PUBLIC WORKS (T.BLK.)
3	7-8-87	D.H.G.	REPLACE 3000 PSI WITH CLASS 'A'
4	1-29-88	D.H.G.	REPLACED DEPARTMENT (T.BLK.)

CONVERSIONS

ENGLISH	METRIC

NOTES:

1. Pre-cut exp. joint material shall be used in all exp. joints.
2. Dummy joints shall be installed at 10 ft. intervals, maximum.
3. Exp. joints shall be installed at 40 ft., maximum.
4. Exp. joints shall be located at ends of radius.
5. Exp. joints shall be located a minimum of 5 ft. from inlet structure.

CITY OF MEMPHIS
DIVISION OF ENGINEERING

DESIGN STANDARD
FOR

VALLEY GUTTER

Qui E. Young 5-7-81
J. J. James 5-7-81
DEPUTY DIRECTOR/CIVIL ENGINEER DATE